


RHIC will be run at low ion beam center-of-mass energies of 7.7 – 20 GeV/nucleon, much lower than the typical operations at 100 GeV/nucleon. The primary motivation is to explore the existence and location of the critical point on the QCD phase diagram. An electron accelerator is being constructed to provide Low Energy RHIC electron Cooling (LEReC) [1] to cool both the blue & yellow RHIC ion beams by co-propagating a 10 – 50 mA electron beam of 1.6 – 2.6 MeV. This cooling facility will include a 400 keV DC gun, SRF booster cavity and a beam transport with multiple phase adjusting RF cavities to bring the beam to one ring to allow electron-ion co-propagation for ~21 m, then through a 180° U-turn electron transport so that the same electron beam can similarly cool the other counter-rotating ion beam, and finally to a beam dump. The injector commissioning is planned to start in early 2017 and full LEReC commissioning planned to start in early 2018. The instrumentation systems that will be described include current transformers, BPMs, profile monitors, multi-slit and single slit scanning emittance stations, time-of-flight and magnetic energy measurements, and beam halo & loss monitors.



Electron Beam Instrumentation

Parameter	Total	Inj	Tr	Mg	Dia	Col	Ex
Profile	13	3	1	1	1	6	1
Charge	4	2			1		1
Current	4	3					2
Position	41	8	9	2	2	17	3
Halo	1	1					
Emittance	3	1				2	
$\Delta p/p$	2			1		1	
Energy	1					1	
Long. Φ	1				1		
Beam Loss	15	4	3	1		5	2

Electron Beam Parameters (Cooling Section)


Parameter	Value
Beam Energy	1.6 – 2.6 MeV
Bunch Charge ($\gamma_{ion} = 4.1 - 6.2$)	100 – 200 pC
Macrobunch Charge (@ 30 – 24 bunches)	3 – 4.8 nC
Average Beam Current	30 – 50 mA
Bunch / Macrobunch Rep. Rates	704 / 9.1 MHz
Bunch Length	80 – 120 ps
Max. Allowable Energy Spread ($\Delta p/p$)	5×10^{-4}
Beam Transvers Size (cooling section)	$\sigma = 3.84$ mm
Normalized emittance	2.5 μ m

Energy Matching

For successful cooling, beam energies require 10^{-4} accuracy. Electron beam energy will be set to an increasing accuracy in the following way.

- set to a 5% accuracy by setting the V_{RF} to an accurate value
- Set to 0.3% accuracy by adjusting V_{RF} based on the magnetic spectrometer measurements
- Set to 0.1% accuracy by adjusting $\Phi_{V,RF}$ based on recombination rates
- Set to 0.01% accuracy by Schottky Spectrum measurements

Energy Measurement Ranges




Beam Pulse Structure

The electron beam has a nested pulse structure [1], where 80 ps bunches at 704 MHz are grouped in macro bunches and positioned to overlap with the 9.1 MHz RHIC ion beam.

Ion beam bunches @ 9.1 MHz rep rate overlapped by

704 MHz electron macro-bunches @ 9.1 MHz rep rate




Schottky Spectrum

Analyzing the Schottky spectrum from the RHIC wall current monitor (WCM), the evidence of cooling can be seen as was done at FermiLab recycler [S. Nagaitsev, et al.]. The Schottky spectrum will be used as a probe to find the precise electron beam energy.

- Inject debunched beam into RHIC: acceptance $\Delta p/p = \pm 4 \times 10^{-3}$
- Electron beam concentrates ions at Electron energy
- Peak forms in Schottky spectrum on Wall Current Monitor
- Adjust LEReC RF to alight energies


Knowing the ion energy to $< 1 \times 10^{-4}$ and measuring the electron energy with respect to the ion energy we, know the electron energy also to $< 1 \times 10^{-4}$



Recombination Monitor

As an indicator of proper alignment of the electron and ion beams for cooling, PIN diodes attached to rate counters will be installed in one of the cold arcs of RHIC to detect radiation from lost Au^{78+} ions from recombination.

- Dispersion bump created using YT (energy transition) quads




- Au^{78+} driven close to wall. & detected by loss monitors.
- Current Au-Au recombination detected proportional to collisions.

Emittance (Injection)

Multi-Slit – Injection Section:

- Automated Analysis,
- 0.5 μ m res. (norm Emit < 2.5 μ m)
- Low Power Operations Only (1 macrobunch / sec)
- Tungsten Slit mask,


Mask 1.5mm thick...
10 x 150 μ m slits @ 1.35mm



Emittance (Cooling)


One in each cooling section, a tungsten single-slit mask is scanned through the beam upstream of a profile monitor that takes images once per second.

- 0.5 mm/s scan over 30 mm beam spot (1 min)
- 2 mm thick tungsten mask
- 1Hz images
- Step Drive
- H+V Slits
- Low impedance chamber



Longitudinal Phase Space

Comprised of a 704-MHz deflecting cavity located just after a 20° dipole and upstream of the mirrorless PM. The $\Delta p/p$ of the macrobunch is displayed on the PM as the dipole expresses the $\Delta p/p$ as horizontal $\Delta\sigma$, and the deflecting cavity tilts the beam to express the beam's longitudinal axis onto the vertical axis. This gives an image of $\Delta p/p$ vs time (or length – z).



Charge & Current

All digitized by Zynq ADC @ 250 MS/s

Faraday Cups

- (3) one for each dump
- (2) end flanges
- (4) Halo Mon's

Integrating Current Xrmf's


- ICT-CF6-60.4
- Shielded ceramic

Fast Current Xfmr's for MPS


- FCT-CF6.75"-96.0-UHV-ARB
- 5.0 V/A Sensitivity
- Tuned to 704MHz with Q=5
- ARB option: 3-mm Slit shield

DCCT (NPCT) Differential Inj-Extr

- NPCT-S-115
- Shielded Ceramic
- 1Hz Average – Slow beam loss



Halo Monitor (Quad)



2 x pair
2 pairs of stepper controlled copper jaws with current measurement from the blades with loss signals from downstream BLMs.


Profile Monitor & Hybrid PM+BPM

PM Key Parameters:

- Cylindrical Vacuum Chamber
- 45 mm screen aperture
- YAG crystal 0.1 X 50 mm
- 50 μ m resolution
- Aluminum coating
- Normal to beam
- Copper mirror @ 45° behind YAG
- Low power (1 macrobunch / sec)


Hybrid PM Functions:

- Absolute Energy
- Beam Profile
- Energy Spread






Beam Position

- 41 Button BPMs (28, 15, 9 mm)
- 16 Libera Single Pass
- 25 + 17 V301 BPM modules (BNL)
 - Ions + Electrons in Cooling (2x17)
 - Position Alarm
 - Time of Flight Energy



V301 Module



PMT BLM electronics developed at JLAB for the 12GeV upgrade will be used for the PMT detectors.

- R11558 side-on PMT
- For MPS & Diagnostics
- 16-bit DAC for LIN & LOG signals
- Response $< 1\mu$ s
- FPGA based & VME interface
- For pulsed beam & CW

Beam Loss



Ion Chamber RHIC style loss monitors.

- 113cc glass tubes
- 0.95 atm of Ar
- Ni electrodes,
- +1400V biased.
- Signals processed by VME electronics developed for RHIC.

