

Harmonically resonant cavity as a bunch-length monitor

Brock F. Roberts


Electrodynamic: 4909 Paseo Del Norte suite D, Albuquerque, NM 87113 (505)-225-9279

Collaborators: Thomas Jefferson National Accelerator Facility (TJNAF). Continuous Beam Electron Accelerator Facility, (CBAF). Center for Injectors and Sources (CIS) and the University of New Mexico, Electrical Engineering Dept. Applied Electromagnetics group.


Publications: Physical review, accelerators and beams **19** ,052801 (2016) and **15**, 122802 (2012)


Research funded by: DOE SBIR DE-SC0009509

Can several harmonic TM_{0N0} modes
be simultaneously superimposed?




Yes, the cavities shape tunes the TM_{0NO} modes to be Harmonic








There are many harmonic geometries!





A single wideband antenna





Beam Monitor

Beam Monitor Evaluation in CEBAF's injector



The detected waveform is the superposition of the cavity modes excited by the beam. The beam can be described in the same format; the compact trigonometric form of their Fourier series



$$v_{detected}(t) = a_{TM_{010}} \cos(w_0 t + \theta_{010}) + a_{TM_{020}} \cos(2w_0 t + \theta_{020}) \dots$$

$$+ a_{TM_{0n0}} \cos(nw_0 t + \theta_{0n0}).$$



$$i_{beam}(t) = a_1 \cos(w_o t + \theta_1) + a_2 \cos(2w_o t + \theta_2) \dots$$

$$+ a_n \cos(nw_o t + \theta_n).$$



Harmonic Cavity Transfer Function




The ratio of these two series is the harmonic cavities transfer function. Once determined, the cavities transfer function can be used to un-distort subsequent data independent of new bunch shapes.




Comparison: Harmonic cavity vs. RF-deflection cavity techniques.




Measuring 499 MHz and 249.5 MHz beams with a 1497 MHz harmonic cavity.



Measurement of two interleaved 499 MHz beams.





CNC Lathe and Vacuum Chuck






Slitting Saw on CNC Mill with 26" rotary



Brazing in Argon Gas





Generation 3 Beam Monitors ready for installation!



Thank you IBIC 2016 and Bergoz!

We are excited to test the new higher bandwidth harmonic cavities and equip CEBAF with high resolution beam monitors.

We hope to demonstrate the use of harmonic cavities in driven applications; fast kickers and bunch modifiers.

Does your accelerator need a non-invasive beam monitor?