

Beam Loss Monitors for Energy Measurements in Diamond Light Source

Niki Vitoratou, Pavel Karataev, Guenther Rehm

John Adams Institute at Royal Holloway, University of London
Diamond Light Source

Niki.Vitoratou.2016@live.rhul.ac.uk
niki.vitoratou@diamond.ac.uk

August 24, 2017



Overview

- 1 Resonant Spin Depolarisation
- 2 Radiation Footprint
- 3 Beam Loss Monitors Setup
- 4 Results
- 5 Future Studies

Resonant Spin Depolarisation (RSD)

- High precision energy measurements technique.
- Sokolov - Ternov effect: The spin of the electrons in a storage ring will develop polarization due to spin flip radiation emission.
- The spin will gradually align antiparallel with the main guide field of the bending magnets.
- Precession frequency of the electron spin depends only on the beam energy:

$$\Omega_z = \omega_0(1 + \alpha\gamma) \quad (1)$$


where ω_0 is the revolution frequency , α the gyromagnetic anomaly of the electron, and $\alpha\gamma$ the spin tune.

Resonant Spin Depolarisation

- The polarised beam is excited by a horizontal magnetic field produced by a vertically oriented stripline.
- The magnetic field oscillates at frequencies which match the fractional part of the spin tune.
- Excitation frequency in resonance with the spin tune → depolarization
- Touschek scattering → Loss mechanism driven by large angle scattering in the electron bunch.

- Electron can exceed the longitudinal acceptance limit.

$$\frac{1}{I(t)^2} \frac{dN}{dt} \propto f_1 + f_2 P(t)^2 \quad (2)$$







Beam Loss Monitor (BLM) parameters

- ① Location
 - downstream the collimators → small physical aperture → electromagnetic showers
- ② Material of the detector
 - high number of counts → better measurement accuracy.
 - fast response for the resonance detection.
- ③ Design
 - capture the largest fraction of the radiation footprint

Radiation Footprint

Radiochromic film

- a layer of radiation-sensitive organic microcrystal monomers on a thin polyester base with a transparent coating.
- absorbed dose $\rightarrow$ film darkening




Beam Loss Monitor Setup

Beam loss detector $\rightarrow$ Light production from charged particles + Light detection

Three beam loss detectors were built and studied.


- Rod 15 cm long 3 cm diameter attached with a photomultiplier.
- Three types of material tested:
 - EJ-204 plastic scintillator
 - Perspex
 - Quartz fused glass (Cherenkov radiator)
- Detectors covered with 1.3 mm lead for low energy x-rays protection.
- Photomultipliers have adjustable voltage gain.



Signal Acquisition


- The detectors are connected with a commercial acquisition instrument with two hardware interfaces:

- coaxial connectors for signal input.
- RJ-25 pinouts for:
 - power supplying
 - gain control voltage




- High impedance input of $50\ \Omega$ for short individual pulses.
- The input is digitised with high speed ADC (125 MHz).
- The ADC data is continuously monitored for the negative peak value.
- Every ADC sample that exceeds the threshold value increments the counter by 1.
- Counter data rate = 10 samples/s

Scintillator EJ204 performance



- Counts/s rate was measured for various beam currents.
- Saturation was observed for high voltage gain.
- Beam current increases $\rightarrow$ the saturation starts earlier.
- Estimate the maximum voltage gain for normal user operation of 300 mA beam current.




Comparison results



- Solid line for beam losses by 300 mA current.
- Dashed line for the background events, when there is no beam.
- Scintillator gives the highest count rate.


BLM performance in RSD

- Normalise the data with the beam losses before the depolarisation.



BLM performance in RSD



- Calculate the expected relative error: $RE = \frac{\sqrt{\text{counts}}}{\text{counts}}$.
- Calculate the rise of the losses after depolarisation.
- Measure the width of the resonance.
- Calculate the std(fit-normalized data).



material	counts/s	RE	rise	width	std
EJ204	$18 \cdot 10^5$	$0.7 \cdot 10^{-3}$	2.2 %	92.4 keV	$(1.8 \pm 0.2) \cdot 10^{-3}$
Perspex	$5.9 \cdot 10^5$	$1.3 \cdot 10^{-3}$	2.3 %	128.6 keV	$(2.3 \pm 0.24) \cdot 10^{-3}$
Quartz	$4.1 \cdot 10^5$	$1.6 \cdot 10^{-3}$	2.1 %	101.9 keV	$(2.4 \pm 0.26) \cdot 10^{-3}$


AdReSD Project and Detector Design

- Advanced Resonant Spin Depolarisation (AdReSD)
- Energy measurements during user time.
- Small dimension beam that does not allow to excite all the bunches during user operation.
- Excite only one part of the beam (some bunches) and depolarise.
- No wait time for the beam to polarise.
- No noticed disturbance of the beam.




Detector Design

- Four detectors around the beam pipe.
- Lightguides to connect the detectors with the photomultipliers.
- Dimensions decided based on the radiation footprint film results.
- Capture the highest fraction of lost particles.



Acquisition improvements


- Consider different counting methods to avoid pile up.
- Test coincidence counting from Touschek particles since they lose and gain an equal amount of momentum.
- Add up the counts from the four blocks.



- Three different materials were studied, with the scintillator EJ204 to be the most efficient in terms of photon output for a given lost particle flux.
- Background studies will be continued in order to avoid counts from other events.
- The design of the detector based on the radiation footprint results will be manufactured.
- Further details of AdReSD project is going to be studied as soon as the detectors setup will be installed.

Thank you for your attention!

$$P = P_0(1 - e^{-\frac{t}{T}}) \quad (3)$$



Polarization coefficients

- $$\frac{1}{\tau} = -\frac{1}{N} \frac{dN}{dt} = \alpha [C(\varepsilon) + F(\varepsilon)P^2]N \quad (4)$$

- $$\varepsilon = \left(\frac{\Delta p_m}{\gamma \sigma_p} \right) \quad (5)$$

- $$C(\varepsilon) = \varepsilon \int_{\varepsilon}^{\infty} \frac{1}{u^2} \left\{ \left(\frac{u}{\varepsilon} \right) - \frac{1}{2} \ln \left(\frac{u}{\varepsilon} \right) - 1 \right\} e^{-u} du \quad (6)$$

- $$F(\varepsilon) = -\frac{\varepsilon}{2} \int_{\varepsilon}^{\infty} \frac{1}{u^2} \ln \frac{u}{\varepsilon} e^{-u} du \quad (7)$$