

Fast Orbit Corrector Power Supply in MTCA.4 Form Factor for Sirius Light Source

Augusto F. Giachero, Gustavo B. Bruno, Lucas M. Russo, Daniel O. Tavares



CNPEM
Centro Nacional de Pesquisa
em Energia e Materiais

IPAC 2021



Brazilian Synchrotron
Light Laboratory

Design Goals

- Correct small beam disturbances up to 1kHz;
- Digital current loop control;
- At least 8 channels for each module;
- Up to $30\mu\text{rad}$ deflection (@ 3GeV);
- Fit into a MicroTCA RTM slot (mid-size);

Requirements

- Small signal bandwidth of 10kHz;
- Maximum total power consumption of 36W;
- Current slew rate of 0.5A/ms (standard) and 0.375A/ms (45°-rotated);
- Total delay of 5 μ S;

Requirements



- Load resistance: 1Ω ;
- Load inductance: 3.5mH (standard) 6.2mH (45°-rotated);
- $\pm 1\text{A}$ output capability per channel;
- Noise Spectral Density:

$$\frac{1.5 \mu\text{A}}{\sqrt{\text{Hz}}} (f \geq 1 \text{ kHz}) \quad \frac{1.5 \mu\text{A}}{\sqrt{\text{Hz}}} \times \frac{1 \text{ kHz}}{f} (f < 1 \text{ kHz})$$

Electronics Design

- Class AB power amplifier;
- 16 bits DAC, 16 bits* ADC;
- Buck converter ($\geq 90\%$ efficient);

* 16 bit differential input ADC, but only the positive range is used.




CNPq
Centro Nacional de Pesquisa
em Energia e Materiais




Brazilian Synchrotron
Light Laboratory

Prototype Validation

- Buck efficiency measured at 92.5%;
- DAC and ADC digital interfaces tested;
- Short circuit protection working;



Prototype Validation (Noise)








CNPq
Centro Nacional de Pesquisa
em Energia e Materiais



Brazilian Synchrotron
Light Laboratory

Prototype Validation (Step Resp.)



1.17Ω 5.9mH load





CNPEM
Centro Nacional de Pesquisa
em Energia e Materiais



Brazilian Synchrotron
Light Laboratory


Magnet Bandwidth



Next steps

- Drive a real corrector magnet;
- Optimize buck converter loop compensation;
- Thermal stress tests;
- Inter-channel crosstalk.

Thank you!



CNPq
Centro Nacional de Pesquisa
em Energia e Materiais



Brazilian Synchrotron
Light Laboratory